ADDENDUM NO. 1

Date: December 9, 2021

To: Design-Build Teams

From: Margie Kennedy, Sr Project Manager
                 Division of Public Works

Subject: DPW Project No. 22204
                 Caven-Williams Turf Replacement
                 Boise State University
                 Boise Idaho

RFQ – ADDENDUM NUMBER ONE

The following addendum applies to the above referenced project and is included as part of the Request for qualifications (RFQ). Acknowledge this addendum within your cover letter of your submittal. Please make certain to include a specific contact name and email address for future correspondence within the cover letter.

Clarifications:
1) This project is an **indoor** practice facility.
2) Costs are **not** required as part of the RFQ submittal. Although, there is an anticipated Project Budget for the project that is indicated in the RFQ.
3) Provide a list of at least **ten (10)** projects that have been completed on ten (10) indoor NCAA game and/or practice football fields, not twenty-five.
4) The existing turf pile height is **2 ½" slim film fiber with 1 ¾" of infill** (silica sand and cyrogenic rubber).
5) The existing turf is **not** laid on a pad. It is laid over crushed rock (road base).
6) The field markings are for football with the Owner's option of additional markings for other sports to be determined.
7) There will **not** be a requirement for logos.
8) The Owner is currently considering for the **Contractor** to demolish and haul off all of the existing turf and infill.
9) The approximate size of the indoor field is **78,000 square feet**.
10) Per Idaho Statue 44-1002 the Contractor must employ 95% **Idaho residents** as employees on any job under any such contract except where under such contracts fifty or less persons are employed the Contractor may employ 10% nonresidents.

END OF ADDENDUM NO. 1